

Water Certificate

2.7
11/07/2023



Government of Karnataka
Executive Engineer Office

Rural Drinking Water and sanitation Division, Raichur

Phone No-08532-221590, email.eerdwsd.rcr@gmail.com

No. EE/RDW&SD/R/Lab/2023-24

1488

Date:-
06 JUL 2023

To,
The Principal
Kendriya Vidyalaya,
Raichur

Respected Sir,

Sub- Submission of water testing report- regarding
Ref: Your office letter Dt- 30-06-2023

With reference to the above subject, given by Principal of Kendriya Vidyalaya Tq. Dist. Raichur. It is certified that the water is safe and suitable for drinking as per chemical testing in Raichur district Laboratory.

Executive Engineer

Rural Drinking water & Sanitation Division
Raichur


2/21/23
प्राचार्य
केन्द्रीय विद्यालय रायचूर

No. 1

GOVERNMENT OF KARNATAKA
RURAL DRINKING WATER SUPPLY AND SANITATION DEPARTMENT-RAICHUR DIVISION

DISTRICT LEVEL WATER QUALITY TESTING LABORATORY
PHYSICAL & CHEMICAL WATER QUALITY TEST REPORT

District	RAICHUR	
Taluka	RAICHUR	
Date of Test	3/7/2023	
Taluka	Raichur	
Location	Kendriya Vidyalaya School	
Type of source	SW	
Type of Scheme	Raw water	
SI.No	Constituents	Indian Standard Drinking water Specification BIS (IS 10500:2012)
		Desirable Limit
		Permissible Limit
	Unit	
	Parameters	
1	Colour	Hazen/ units 5
2	Odour	Agreeable
3	Taste	Agreeable
4	Turbidity	5
5	Fluoride(FI)	1.5
6	Nitrate	45
7	Sulphate	400
8	Iron(Fe)	1
9	Chloride (Cl)	1000
10	Total Alkalinity	600
11	Calcium (Ca)	200
12	Magnesium (Mg)	100
13	pH	8.5
14	TDS	2000
15	Total Hardness	600
16	Bacteria	-
		Result
		Potable


EXECUTIVE ENGINEER
RDW&S DIVISION RAICHUR

2/11/23
प्रचार्य
केन्द्रीय विद्यालय रायचूर